



## Invitation to Bid

### ITB: #2026-02-05 Huntington City Hall Cooling Tower Replacement

The City of Huntington West Virginia is soliciting bids from licensed contractors for the removal and replacement of the cooling tower at City Hall located at 800 5<sup>th</sup> Avenue Huntington West Virginia.

A mandatory site visit will be conducted on Tuesday March 17<sup>th</sup>, 2026, at 10:00 AM local time at City Hall and will be held in city council chambers. All questions shall be submitted through Bidexpress.com by 2:00 pm local time on Friday March 20<sup>th</sup>, 2026.

City of Huntington will accept bids to provide the cooling tower replacement until 10:00 am on Wednesday March 25<sup>th</sup>, 2026, and should be submitted through BidExpress.com. At that time, bids will be opened at City Hall, 800 5<sup>th</sup> Avenue, room 135, City Clerk's Office, Huntington, WV.

#### Minimum Specifications for Bids

1. Vendors to provide labor and materials necessary to complete the work as outlined
2. Vendor to haul and dispose of all debris
3. Minimum Warranty: the manufacturer's material warranty. This information shall be provided to the City of Huntington
4. Bid (5%), Payment and Performance Bonds will be required.

#### Final Appearance and Clean-Up

Installer shall not allow debris to blow away from the construction site and shall be picked up and removed from the site or placed within a proper receptacle on a daily basis. Work area will be left broom clean at end of installation.

#### Cooling Tower Replacement Specifications

- Provide an exact replacement Bap cooling tower to job site
- Disconnect existing tower
- Remove and properly dispose of tower
- Provide crane for removal and replacement
- Replace 4 X 6 I-beams support
- Repaint angle and channel beams
- Install new walkway steel on back side and right side
- Reinstall railway in front of tower and replace supports
- Install and reconnect new cooling tower



- Including supply, return, make up water, overflow, chemical feed, spray pump, and all electrical power and control wiring
- Start up and test operation of system

Any questions in regard to the use of BidExpress may be directed to Dan Underwood, Purchasing Director, at 304.696.5540 ext. 2015 or by email at [dunderwood@huntingtonwv.gov](mailto:dunderwood@huntingtonwv.gov).